

**PUBLIC HEALTH ENGINEERING DEPARTMENT**  
**DISTRICT WATER TESTING LABORATORY, FARIDABAD**



Website :- <https://phedharyana.gov.in/>

Date:- 20/2/2023

Memo No:- 69

**Subject : Bacteriological Examination Report of Water Sample**

Sample ID: FBD/03974/2/2023		Sample Details	Date & Time
Sample Classification: Private		Collected By	,8600467084
Sender: Jawahar Navodaya Vidyalaya, Mothuka, Faridbad 18486		Collection Date	14/02/2023 at 11:03
Location :- , Jawahar Navodaya Vidyalaya, Mothuka, Faridabad		Received at lab	14/02/2023 at 12:20
Latitude :- 77.357168	Longitude :- 28.286790	Tested at Lab	20/02/2023

Test Result (As Per BIS 10500 :2012)			Protocol Used
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)
1	Total Coliform per 100 ml	0	Shall not be detectable in any 100 ml sample
			IS 15185:2016/ APHA 9221C; 2017

**Remarks :-**

- \* The Results Given above are related to the sample as received and tested in FARIDABAD lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.

Water Sample has been found **"CONFORMING"** to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters, the water sample is found **"POTABLE"**



*Vandana*  
 VANDANA DESWAL, CHEMIST  
 PUBLIC HEALTH ENGINEERING DEPARTMENT  
 DISTRICT WATER TESTING  
 LABORATORY FARIDABAD  
 email:- chemist.fbad@phedharyana.gov.in

-----End of Report-----

*20/2/23*  
*Sum*  
*2/2*